



- APPLICATION NOTES:**
- 1) TWO TRACK CHANNELS EACH CAPABLE OF TWO, 20 AMP, 120 VOLT CIRCUITS
 - 2) PROVIDE SUPPLY WIRE SUITABLE FOR 75°C
 - 3) 4' MAXIMUM SPACING BETWEEN HANGERS

DESIGNED BY	DATE		41-80 2nd STREET L.C. NY 11101 TEL 718.688.0700 FAX 718.706.1628 E-MAIL DESIGN@EPL.COM
DRAWN BY	DATE		
SUBMITTED BY	DATE	PROJECT	
FITTURE DOUBLELINE R		REVISION SCALE BOX # DWG SIZE SHR. OF DWG	
ORDER #		DWG #	

6 5 4 3 2 1

A B C D E F

6 5 4 3 2

A B C D E F

File Name: DLINE R